

पिछली - 1172 निम्न
Municipal Corporation of Delhi
Civil Lines Zone, Health Dept.

Dated 27.10.1979.

No. 1172 HO/79/1768

The Principal,
Sant Nirankari Girls Sr. Sec. School,
Sant Nirankari Colony,
Delhi-110009.

Subject - Health Certificate

I acknowledge the receipt of your letter no. MCD 79-80/241 dtd 10.10.79. In view of the report submitted by S.I. (L) the undersigned is pleased to issue a (NO OBJECTION CERTIFICATE) for your school from the health point of view.

Sd.

(Dr. P. K. Sharma)
Zonal Health Officer,
Civil Lines Zone

Attested True Copy

S. Ananya

2/12/79

Principal
Sant Nirankari Girls Sr. Sec. School
Sant Nirankari Colony, Delhi-110009

Principal
Sant Nirankari Girls Sr. Sec. School
Nirankari Colony, Delhi-110009

Manager

14/16/22

S. S. K. Singh

Performa for Joint Inspection of RWH system in Govt./Pvt. Schools/colleges in Delhi on NGT direction on 16.11.17 in O.A. No. 217/2016.

1. Name and address of unit: Sant Nirankari Senior Sec school / boys and girls /
 2. Area detail :
 i) Roof top area: 2420 m² app
 ii) Paved/road/green area (optional)
 iii) Total Plot area: 7967 m² app
Sant Nirankari colony
near Dhisapur
N. Delhi - 9

3. Date of inspection: 28/2/18

(The status given below is as on inspection date)

S.No.	Govt./Pvt.	RWH system exist or not	Status of RWH system, if exist				Remarks	
			Nos. of pit	Size of pit	No. & size of recharge well	Whether Functional Yes/No		Adequate Yes/No
1.	Govt aided	yes	7 nos	4 x 4 x 2.8 m x 2.10 2 x 1.5 x 1.80 x 2.00 m 1 x 5 x 2 x 2 m <u>7 nos</u>	N/A	yes	yes	Periodical upkeep advised

[Signature]
 Principal
 Sant Nirankari Girls Sr. Sec.S
 Nirankari Colony, Delhi-110009

[Signature]
 Man

04/5
28-2-18
JGT A 217(16)

[Signature]
VIMAL V. BELANI
 Asstt. Engineer (C)
 Delhi Jal Board
 (GNCTD)

[Signature]
 Principal
 Sant Nirankari Girls Sr. Sec. Scho
 Nirankari Colony, Delhi-09

[Signature]
P.F. Gupte
 Sr. Hydrogeologist
 (Scientist-D)
 CGWB, SDO, Delhi

[Signature]
 Principal
 Sant Nirankari Girls Sr. Sec. School
 Nirankari Colony, Delhi-110009